### DELLENT SDEC Diesel Generator Three Phase Silent Diesel Generator 50kW 50Hz

### **Basic Information**

Place of Origin: CHINA
Brand Name: DELLENT
Certification: CE/ISO9001
Model Number: DE-SC63
Minimum Order Quantity: 1\*20GP
Price: face to face

Packaging Details: PLASTIC WRAP OR PLYWOOD CASE
 Delivery Time: 30 DAYS FROM DEPOSIT RECEIVED

Payment Terms: L/C, T/T

• Supply Ability: 500 PCS PER MONTH



### **Product Specification**

Name: SDEC Diesel Generator Three Phase

Engine Model: 4HT4.3-G21Frequency: 50HzEngine Brand: SDEC

• No. Of Cylinder: 4 Cylinder In Line

Rated Speed: 1500rpmVoltage: 400V/230VWarranty: 12 Months

Controller: Automatic Start/Stop

Prime Power: 45kW/56kVA
Standby Power: 50kW/63kVA
Alternator Type: Brushless

• Highlight: SDEC Diesel Generator 50kW,

SDEC Diesel Generator Three Phase, Silent Diesel Generator 50kW

# Three Phase SDEC Engine 50Hz 50kW Silent Diesel Generator

### .PRODUCT DESCRIPTION

50kVA Standby Power SDEC Genset Soundproof Engine By 4 Cylinder In Line. Dellent Power supply the standby power 50kVA water cooled diesel generator with SDEC brand diesel engine model4HT4.3-G21. The water cooled diesel generator with rated output 56kVA /45kW, standby power63kVA /50kW.



- 1: Efficient and energy-saving: Diesel engines have higher thermal efficiency than gasoline engines, allowing for more efficient use of fuel;
- 2: Strong load capacity: Diesel engines have high torque and can work stably under high loads, making them suitable for power supply of high-power equipment;
- 3: High reliability: The diesel engine has a simple structure, good durability, and low maintenance cost;
- 4: High safety: diesel fuel is not flammable or explosive, relatively safe;
- 5:Strong adaptability: Diesel generators can work under various environmental conditions with strong adaptability.

#### 50kVA Diesel Generator Powered by SDEC Diesel Engine:

Model		DE-SC63		
Max. Power	kVA	63		
iviax. Fower	kW	50		
Rate Power	kVA	56		
	kW	45		
Frequency	Hz	50		
Rate Voltage	V	400/230		
Rate Current	Α	80.83		
Chariffestion of the Discol Engine				

#### Specification of the Diesel Engine:

Specification of the bleser Engine.					
Engine Manufacturer		Shanghai Diesel Engine Co., Ltd.			
Engine Brand		SDEC			
Engine Model		4HT4.3-G21			
No. of Cylinder		4 Cylinder in line			
Aspiration		Turbocharged			
Governor		Electric			
Engine Max. Output Power	kW	56			
Displacement	L	4.300			
Starting Voltage	V	24			
Bore	mm	105			
Stroke	mm	124			

Lubrication Oil Capacity	L	11-13
Compression Ratio		17.3 : 1
Intake Air Flow	M <sup>3</sup> /Min	N.A
Fuel Consumption at 100% Load	L	12.8

**Specification of Automatic Control Panel:** 

Controller Brand		ComAp		
Breaker Brand		Delixi		
Breaker Capacity	А	63		
Battery Charger		Smartgen Model BAC06A		
Emergency Stop Button		Supply		
Automatic Mains Fail (AMF)		Supply		
Fuel Level		Supply		
Automatic Transfer Switch		ATS as optional part		
Mains Monitor	Su	Supply with DELLENT Function		

The control panel supply the full protection with alarm and shutdown of the diesel generator include Start-up fault (generator set shutdown), High coolant temperature (alarm and generator set shutdown), Low oil pressure (alarm and generator set shutdown), Low fuel level (alarm), Low cooling fluid level alarm (as optional), Overload (alarm and generator set shutdown), Battery voltage high (alarm).

Optional controller: Each model of Deepsea, Smartgen, ComAp brand controller.

### . Why Choose Us:



We are DEDICATED to meet Customers' need.

## **Enthusiasm**

We respond to our Customers' ENTHUSIASM

# Loyalty

We cherish our Customers' LOYALTY

## Luxury

We aim to establish our own LUXURY brand

## efficient

We offer our EFFICIENT service

## Newest

We adopt NEWEST technologies for products



We strive for winning the TRUST from Customers

. QUALIFICATION CENTIFICATE:



















### . FACTORY INTERIOR:















- 1: The diesel generator should be placed in a well ventilated area to ensure heat dissipation;
- 2: The diesel generators should regularly inspect and replace vulnerable parts such as engine oil and air filter elements to ensure their normal operation;
- 3: When running diesel generators, attention should be paid to the quality and storage method of fuel, to avoid using inferior fuel or improper storage that may cause malfunctions;



### Fuan Dellent Electric & Machinery Co., Ltd.





jennifer@dellent.com



dellentpower.com

NO.7, JINYE ROADTIEHU INDUSTRIAL AREA CHENGYANG TOWN, FUAN CITY, NINGDECITY, FUJIAN. CHINA